



ELECTRICAL APPLIANCE TEST & INSPECTION REPORT

FUNDAY ENTERTAINMENT LTD

**CREASEYS FARM
CHURCH LANE
HUTTON, BRENTWOOD
ESSEX
CM13 1RZ**

29 April 2019

**Head Office and National Control Centre:
11 Crab Marsh
Wisbech
Cambridgeshire
PE13 3JG**

**Telephone: 0800 84 888 22
Fax: 01945 738 001
[e-mail: service@purepat.com](mailto:service@purepat.com)**



Electrical Portable Appliance Inspection & Testing

ELECTRICAL SAFETY ADVICE

Thank you for choosing NSS Pure-PAT to carry out your Electrical Portable Appliance Testing.

Please be aware that although we have Inspected and Tested the appliances on the enclosed Test & Inspection schedule there are still further precautions you should take to minimise the risk of any appliance causing a fire or electric shock.

- **IMPORTANT: Integrity of Fixed Electrical Wall Sockets**

Part of the PAT Testing procedure is to test the earth continuity of appliances that require to be continuously earthed. The earth continuity of an appliance is a very important built in safety feature that should take away the risk of a person receiving a shock should the appliance develop an electrical fault.

This safety feature can only work correctly providing the earth connection to the fixed wall socket is also properly connected otherwise there is a risk of an electric shock even if the actual appliance has been passed as safe.

Fixed wall sockets can have as many as 17 different fault combinations, therefore if you have not had the wall sockets tested within the past three years we would recommend that they are tested on our next visit. If you require any help or advice please contact us.

- **Remember Water and Electricity are not a safe combination!**

In areas such as kitchens and staff rooms it is imperative that water does not come into contact with any electrical current – always ensure that your hands are dry before connecting or switching on any electrical appliance – this includes the sockets and switches that are mounted on the wall.

- **Extension Leads**

Extension leads that are used in the workplace should have a Residual Current Device (RCD) permanently fitted if the extension lead is more than 15 metres in length.

Do not use high energy Fan Heaters or Radiators in multi-socket extension leads – the maximum combined wattage of all appliances in multi-socket extension leads should not exceed 3000 watts.

It is not good practice to have extension leads sited on floors or anywhere near where water or liquid has a high risk of spillage.

Coiled extension leads generate heat – the greater the coil the greater the heat. Coiled extension leads should NOT be used continuously - far better to have a made to measure or fully unwound lead than a coiled lead.

- **FAILED or Damaged Appliances**

On NO account should you continue to use any damaged or faulty electrical appliances that have failed our tests – you are risking the possibility of a fire or electric shock.

The above are just a small sample of measures that can be taken to ensure the safety of everyone who comes into contact with electrical appliances.



CERTIFICATE OF
ELECTRICAL APPLIANCE TESTING

CERTIFICATE NO:
19/2904

FUNDAY ENTERTAINMENT LTD

**CREASEYS FARM
CHURCH LANE
HUTTON, BRENTWOOD
ESSEX
CM13 1RZ**

This certificate confirms that the Portable Electrical Appliances that are listed on the enclosed test records and have Pure-PAT identification labels attached to the appliance at the above named premises have been formally Inspected, Checked and Tested for Electrical Safety using the guidelines as required by the Health & Safety Executive (HSE) and taking into account the requirements of the Health & Safety at Work Act 1974, the provision and Use of Work Equipment Regulations 1998 and the Electricity at Work Regulations 1989.


CERTIFICATE VALID UNTIL 29 APRIL 2020


A handwritten signature in black ink, consisting of several loops and a long horizontal stroke, is written over a dashed line.

AUTHORISED SIGNATORY

Pure-PAT Electrical Testing Ltd
11 Crab Marsh
Wisbech, Cambs PE13 3JG
Tel: 01945 738151
E-mail: service@purepat.com

PORTABLE APPLIANCE TESTING REPORT

<div></div> <div>Pure-PAT Electrical Testing Ltd 11 Crab Marsh, Wisbech, Cambridgeshire PE13 3JG Telephone: 01945 738151 e-mail: service@purepat.com</div>				NO:		19/2904		FUNDAY ENTERTAINMENT LTD CREASEYS FARM CHURCH LANE HUTTON, BRENTWOOD ESSEX CM13 1RZ			
				DATE:		29 April 2019					
ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST EARTHINSULATION		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS	
34321	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34322	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34323	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34324	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34325	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34326	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34327	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34328	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34329	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34330	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34331	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34332	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34333	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34334	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34335	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34336	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34337	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34338	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34339	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34340	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34341	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34342	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34343	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34344	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34345	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34346	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34347	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34348	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		
34349	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS		

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
34350	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34351	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34352	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34353	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34354	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34355	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34356	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34357	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34358	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34359	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34360	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34361	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34362	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34363	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34364	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34365	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34366	4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34367	Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34368	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34369	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34370	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34371	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34372	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34373	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34374	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34375	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34376	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34377	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34378	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34379	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34380	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34381	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34382	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34383	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34384	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34385	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34386	4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34387	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34388	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
34389	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34390	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34391	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34392	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34393	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34394	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34395	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34396	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34397	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34398	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34399	16a 4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34400	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34401	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34402	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34403	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34404	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34405	16a 2 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34406	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34407	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34408	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34409	16a Karcher Pressure Washer	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34410	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34411	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34412	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34413	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34414	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34415	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34416	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34417	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34418	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34419	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	Plug Re-fit
34420	4 Gang Extension Lead	Store	1						FAIL	Damaged Casing (Disposed)
34421	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	New 16a Plug Fitted
34422	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	New 16a Plug Fitted
34423	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	New 16a Plug Fitted
34424	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	New 13a Plug Fitted
34425	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	New 13a Plug Fitted
34426	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	New 16a Plug Fitted
34427	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
34428	Speakers	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34429	Ice Cream Freezer	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34430	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34431	Dehumidifier	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34432	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34433	Pump	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34434	IEC Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34435	Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34436	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34437	Computer	Mezzanine - Office	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34438	IEC Power Lead	Mezzanine - Office	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34439	6 Gang Extension Lead	Mezzanine - Office	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34440	Power Supply Unit	Mezzanine - Office	2	PASS		PASS	PASS	29/04/2020	PASS	
34441	Power Supply Unit	Mezzanine - Office	2	PASS		PASS	PASS	29/04/2020	PASS	
34442	IEC Power Lead	Mezzanine - Office	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34443	Speakers	Mezzanine - Office	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34444	Heater	Mezzanine - Office	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34445	Power Supply Unit	Mezzanine - Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34446	16a Extension Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34447	Speakers	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34448	AC Adaptor	Mezzanine - Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34449	Speakers	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34450	IEC Power Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34451	Speakers	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34452	Speakers	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34453	Speakers	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34454	Speakers	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34455	Power Supply Unit	Mezzanine - Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34456	Lamp	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34457	Lamp	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34458	Lamp	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34459	IEC Power Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34460	Lamp	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34461	Male / Female IEC Power Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34462	Male / Female IEC Power Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34463	Male / Female IEC Power Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34464	IEC Power Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34465	IEC Power Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34466	IEC Power Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
34467	IEC Power Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34468	Power Supply Unit	Mezzanine - Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34469	Power Supply Unit	Mezzanine - Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34470	Blower	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34471	Speakers	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34472	IEC Power Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34473	4 Gang Extension Lead	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34474	Air Vortex	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34475	Air Vortex	Mezzanine - Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34476	Lamp	Mezzanine - Store	2	PASS		PASS	PASS	29/04/2020	PASS	
39861	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39862	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39863	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39864	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39865	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39866	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39867	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39868	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39869	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39870	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39871	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39872	16a 3 Way Adaptor	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39873	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	New 16a Plug Fitted
39874	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39875	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39876	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39877	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39878	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39879	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39880	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39881	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39882	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39883	Air Hockey Table	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
39884	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39885	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39886	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39887	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39888	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39889	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
39890	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39891	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39892	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39893	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39894	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39895	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39896	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39897	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39898	Power Supply Unit	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
39899	Gunslinger	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
39900	Blower	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	New 13a Plug Fitted
39901	Blower	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
39902	16a Blower	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
39903	16a Blower	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
39904	230v -110v Transformer	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39905	Rodeo Machine	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
39906	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39907	Horse Racer	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
39908	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
39909	Horse Racer	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
39910	Lights	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33801	Lights	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33802	Lights	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33803	Lights	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33804	Lights	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33805	Lights	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33806	Lights	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33807	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33808	3 Core Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33809	Stump Supply	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33810	2 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33811	16a Control Panel	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33812	415v 16a Extension Lead	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33813	415v 16a Machine	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33814	230v 16a - 415v 16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33815	415v 16a Roller Machine	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33816	32a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33817	32a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33818	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
33819	20m Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33820	16a Control Panel	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33821	Euro Adaptor	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33822	Euro Air Pump	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33823	415v Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33824	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33825	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33826	4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33827	AC Adaptor	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33828	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33829	Projector	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33830	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33831	Computer	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33832	Heater	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33833	16a Control Panel	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33834	Power Supply Unit	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33835	Power Supply Unit	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33836	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33837	16a-13a 4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33838	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33839	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33840	4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33841	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33842	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33843	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33844	16a-13a 30m Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33845	8 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33846	RCD	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33847	Light	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33848	Light	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33849	Light	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33850	Light	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33851	Light	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33852	Light	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33853	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33854	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33855	6 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33856	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33857	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
33858	Wii Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33859	RCD	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33860	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33861	TV	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33862	Rodeo Control	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33863	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33864	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33865	16a Blower	Store	1						FAIL	Exposed Cable
33866	6m Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33867	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33868	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33869	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33870	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33871	Visual Display Unit	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33872	Light	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33873	Light	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33874	Photo Printer	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33875	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33876	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33877	Clover Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33878	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33879	6 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33880	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33881	Hockey Table	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33882	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33883	Hockey Table	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33884	LED Light	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33885	AC Adaptor	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33886	AC Adaptor	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33887	AC Adaptor	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33888	AC Adaptor	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33889	AC Adaptor	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33890	32a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33891	16a Blower	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33892	16a Blower	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
33893	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33894	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33895	AC Adaptor	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33896	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
33897	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33898	16a 2 Way Adaptor	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33899	16a 3 Way Adaptor	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33900	16a-13a 4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33901	16a-13a 2 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33902	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33903	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33904	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33905	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33906	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33907	1 Gang Extension Lead	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	Socket Tested
33908	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33909	TV	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33910	PS4	Store	2	PASS		VISUAL	PASS	29/04/2020	PASS	
33911	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33912	Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33913	Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33914	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33915	Power Supply Unit	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33916	1 Gang Extension Lead	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	Socket Tested
33917	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33918	TV	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33919	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33920	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33921	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33922	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33923	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33924	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33925	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33926	Power Supply Unit	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33927	AC Adaptor	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33928	Clover Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33929	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33930	Extension Lead	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	Socket Tested
33931	Yamaha Subwoofer	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33932	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33933	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33934	1 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33935	6 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
33936	Sign	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33937	TV	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
33938	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33939	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33940	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33941	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33942	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33943	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33944	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33945	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33946	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33947	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	New 16a Plug Fitted
33948	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33949	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33950	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33951	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33952	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33953	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33954	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33955	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33956	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33957	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33958	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33959	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33960	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33961	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33962	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33963	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33964	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33965	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33966	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33967	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33968	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33969	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33970	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	New Socket Fitted
33971	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33972	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33973	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33974	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
33975	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33976	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33977	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33978	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33979	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33980	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33981	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33982	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33983	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33984	16a-13a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33985	4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33986	4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33987	Smoke Machine	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33988	Smoke Machine	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33989	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33990	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33991	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33992	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33993	Male / Female IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33994	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33995	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33996	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33997	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33998	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
33999	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34000	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34001	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34002	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34003	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34004	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34005	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34006	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34007	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34008	16a Blower	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34009	Hot Dog Cart	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34010	Food Warmer	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34011	Heater Spike	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34012	Heater Spike	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34013	5m Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
34014	Kettle Base	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34015	Kettle	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34016	Hot Plate	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34017	Lights	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34018	Microwave	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34019	Food Warmer	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34020	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34021	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34022	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34023	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34024	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34025	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34026	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34027	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34028	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34029	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34030	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34031	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34032	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34033	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34034	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34035	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34036	16a 4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34037	16a-13a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34038	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34039	AC Adaptor	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34040	16a-13a 4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34041	3 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34042	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34043	Rodeo Machine	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34044	Surf Simulator	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34045	16a Control Panel	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34046	Control Panel	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34047	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34048	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34049	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34050	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34051	13a-16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34052	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
34053	13a-16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34054	13a-16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34055	16a Junction Box	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34056	16a-13a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34057	16a-32a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34058	16a-32a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34059	32a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34060	32a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34061	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34062	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34063	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34064	32a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34065	32a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34066	32a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34067	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34068	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34069	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34070	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34071	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34072	16a Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34073	16a IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34074	16a-13a 4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34075	16a-13a 4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34076	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34077	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34078	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34079	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34080	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34081	16a Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34082	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34083	Speakers	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34084	Moon Glow Light	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34085	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34086	13a-16a	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34087	16a-13a 4 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34088	230v Supply Splitter	Store	1						FAIL	Smashed
34089	16a Extension Lead	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34090	32a Supply Splitter	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34091	AC Adaptor	Store	2	PASS		PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
34092	2 Core Power Lead	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34093	Power Supply Unit	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34094	Vacuum	Store	2	PASS		PASS	PASS	29/04/2020	PASS	
34095	16a 3 Gang Extension Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34096	Dehumidifier	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34097	Skate Sharpener	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34098	IEC Power Lead	Mezzanine Store Room / CCTV	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34099	Visual Display Unit	Mezzanine Store Room / CCTV	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34100	AC Adaptor	Mezzanine Store Room / CCTV	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34101	IEC Power Lead	Mezzanine Store Room / CCTV	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34102	Power Supply Unit	Mezzanine Store Room / CCTV	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34103	Water Boiler	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34104	Water Boiler	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34105	Water Boiler	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34106	Chocolate Marshmallow Machine	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34107	Crepe Maker	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34108	Crepe Maker	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34109	Soup Kettle	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34110	Soup Kettle	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34111	Popcorn Machine	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34112	Popcorn Machine	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34113	Popcorn Machine	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34114	Candyfloss Machine	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34115	Popcorn Machine	Mezzanine Store Room	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34116	IEC Power Lead	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34117	Candyfloss Machine	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34118	13a-16a	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34119	16a IEC Power Lead	Mezzanine Store Room	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34120	Fridge	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34121	Microwave	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34122	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34123	16a Space Heater	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34124	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34125	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34126	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34127	16a-13a 4 Gang Extension Lead	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34128	AC Adaptor	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34129	Spot Lamp	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34130	Spot Lamp	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
34131	Spot Lamp	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34132	Spot Lamp	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34133	Spot Lamp	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34134	16a Task Lamp	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34135	16a Task Lamp	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34136	16a Task Lamp	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34137	Euro Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34138	Titan Charger	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34139	Start Charger	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34140	Start Charger	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34141	Blower	Mezzanine	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34142	IEC Power Lead	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34143	Smoke Machine	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34144	Show Lights	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34145	Show Lights	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34146	Show Lights	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34147	Show Lights	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	New Plug Fitted
34148	IEC Power Lead	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34149	Speakers	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34150	IEC Power Lead	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34151	Speakers	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34152	IEC Power Lead	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34153	Power Supply Unit	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34154	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34155	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34156	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34157	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34158	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34159	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34160	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34161	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34162	Jigsaw	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34163	16a Site Lights	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34164	16a Site Lights	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34165	16a Site Lights	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34166	16a Site Lights	Mezzanine	1						FAIL	Broken Casing
34167	Power Supply Unit	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34168	IEC Power Lead	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34169	Power Supply Unit	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
34170	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34171	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34172	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34173	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34174	16a Blower	Mezzanine	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34175	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34176	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34177	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34178	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34179	16a Blower	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34180	IEC Power Lead	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34181	Snow Machine	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34182	IEC Power Lead	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34183	Power Supply Unit	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34184	Power Supply Unit	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34185	Power Supply Unit	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34186	AC Adaptor	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34187	Compressor	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34188	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34189	AC Adaptor	Mezzanine	2	PASS		PASS	PASS	29/04/2020	PASS	
34190	13a-16a	Mezzanine	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34191	Kettle Base	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34192	Kettle	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34193	Compressor	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34194	Power Lead	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34195	Power Lead	Store	1	PASS	VISUAL	VISUAL	PASS	29/04/2020	PASS	
34196	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34197	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34198	IEC Power Lead	Store	1	PASS	PASS	PASS	PASS	29/04/2020	PASS	
34199	Polisher	Store	1						FAIL	Exposed Copper

Total	605
Failed	5
Passed	600